HOUSE DOCKET, NO. 2213 FILED ON: 1/17/2013

HOUSE . . . . . No. 2924

The Commonwealth of Massachusetts

PRESENTED BY:

Nick Collins

To the Honorable Senate and House of Representatives of the Commonwealth of Massachusetts in General Court assembled:

The undersigned legislators and/or citizens respectfully petition for the passage of the accompanying:

An Act promoting the safe operation of utility vaults.

PETITION OF:

NAME:	DISTRICT/ADDRESS:
Nick Collins	*4th Suffolk*
Carl M. Sciortino, Jr.	*34th Middlesex*
Tackey Chan	*2nd Norfolk*
Lori A. Ehrlich	*8th Essex*
John F. Keenan	*Norfolk and Plymouth*
Martin J. Walsh	*13th Suffolk*
Christine E. Canavan	*10th Plymouth*
Geoff Diehl	*7th Plymouth*
John J. Lawn, Jr.	*10th Middlesex*
John P. Fresolo	*16th Worcester*
Edward F. Coppinger	*10th Suffolk*
Walter F. Timilty	*7th Norfolk*
Timothy J. Toomey, Jr.	*26th Middlesex*
Kate Hogan	*3rd Middlesex*
Thomas M. Stanley	*9th Middlesex*

HOUSE DOCKET, NO. 2213 FILED ON: 1/17/2013

HOUSE . . . . . No. 2924

By Mr. Collins of Boston, a petition (accompanied by bill, House, No. 2924) of Nick Collins and others relative to the safe operation of utility vaults. Telecommunications, Utilities and Energy.

The Commonwealth of Massachusetts

An Act promoting the safe operation of utility vaults.

Be it enacted by the Senate and House of Representatives in General Court assembled, and by the authority of the same, as follows:

SECTION 1: Chapter 166 of the General Laws is amended by inserting after section 34 the following sections:-

"Section 34A. Definitions

'Company' shall mean a distribution company or electric company as defined in section 1 of chapter 164.

'Inspector' shall mean one or more employees of a municipality, including the inspector of buildings, building commissioner or local inspector of a city, town or district or a municipal inspector of wires appointed under section 32. An Inspector shall not be employed by or otherwise associated with an Owner or a Company.

'Owner' shall mean the owner of property on which a Transformer Vault is located; except that 'Owner' shall not include any 'Company' as defined in this section.

'Transformer Vault' or 'Vault' shall mean a totally enclosed structure or room in which energized network transformers, network protectors and related equipment are housed.

Section 34B. Application

Sections 34A through 34G, inclusive, shall apply to all Transformer Vaults owned, leased or otherwise controlled by an Owner and which contain equipment owned, maintained, repaired or operated by a Company, but shall not apply to Company Transformer Vaults

Section 34C. Scope

Sections 34A through 34G provide for the structural and related standards and requirements for Transformer Vaults. All Transformer Vaults shall comply with these sections.

Section 34D. Access

The Transformer Vault shall be accessible at reasonable hours to any Inspector and to the Company.

Section 34E. Standards

Transformer Vaults shall meet the following requirements:

(a) The Vault space shall be large enough to accommodate the transformer(s) and other equipment located within the Vault.

(b) The walls, wall partitions and roofs of Vaults shall be constructed of materials that have adequate structural strength for the conditions with a minimum fire resistance of 3 hours.

(c) Each doorway leading into a Vault from the building interior or out of a Vault to the building interior shall be provided with a tight-fitting door that has a minimum fire rating of 3 hours. The Inspector may also require a fire-rated door for an exterior wall opening where conditions warrant. Each door shall be properly hinged and self-closing.

(d) Doors shall be equipped with locks, and doors shall be kept locked, access being allowed only to qualified persons. Personnel doors shall swing out and be equipped with panic bars, pressure plates, or other devices that are normally latched but that open under simply pressure.

Sidewalk hatches located within or above Transformer Vaults shall be made accessible by ladders composed of fire and heat resistant materials. The location of doorways shall be marked with reflective tape located on the floors and doors. All doorways shall be marked with a sign reading 'DANGER – HIGH VOLTAGE WITHIN – KEEP OUT – ACCESS RESTRICTED TO QUALIFIED PERSONS ONLY.'

(e) Transformer Vaults shall be constructed so as to maintain adequate ventilation of the Vault in the event of smoke or other unsafe condition. Ventilation openings shall be covered with durable gratings, screens, or louvers, according to the treatment required in order to avoid unsafe conditions yet still provide for adequate ventilation of the Vault. All ventilation openings to the indoors shall be provided with automatic closing fire dampers that operate in response to a Vault fire. Ventilating ducts shall be constructed of fire resistant material.

(f) Vaults shall contain 24-hour lighting with an alternate power source.

(g) Vaults shall be equipped with smoke detectors, carbon dioxide detectors, grounding systems, convenience, and heat detection systems.

(h) Materials shall not be stored in Transformer Vaults.

Section 34F. Inspections

An Inspector shall have the right to inspect any Transformer Vault located within the Inspector's jurisdiction at any time, upon giving the Owner and the Company reasonable notice of the inspection. Representatives of the Owner and the Utility shall be present at the inspection. The Inspector shall inspect the Transformer Vault to ensure that the Transformer Vault meets the standards set forth herein. Should the Inspector find that the Transformer Vault does not conform to the provisions of these sections in any material way, the Inspector shall inform the Owner of items which do not so conform and which require maintenance or repair. The Owner shall maintain or repair such items requiring same. After completion of any required maintenance and repairs, the Inspector shall perform a reinspection to ensure that the required maintenance and repairs have been completed. All inspection and reinspection fees shall be paid by the Owner of the Transformer Vault to the municipality.

Section 34G. Violations

If upon reinspection the Inspector determines that the Owner has willfully or negligently failed within a reasonable time to perform any maintenance or repair required as a result of an inspection, such Owner shall be punished by a fine of not more than one thousand dollars.".